

Fiemme 3000 - DKZ Srl  
Via dell' Artigianato 18  
Predazzo TN  
ITALY

Eurofins Product Testing A/S  
Smedeskovvej 38  
8464 Galten  
Denmark

CustomerSupport@eurofins.com  
www.eurofins.com/VOC-testing

## VOC EMISSION TEST REPORT


### Indoor Air Comfort GOLD<sup>®</sup>

22 May 2019

#### 1 Sample Information

Sample name	BOSCHI DI FIEMME – ROVERE COLORATO
Batch no.	-
Production date	26/03/2019
Product type	Other flooring
Sample reception	03/04/2019

#### 2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Regulation of March and May 2011 (DEVL1101903D and DEVL1104875A)
French CMR components	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
AgBB/ABG	Pass	Anforderungen an bauliche Anlagen bezüglich des Gesundheitsschutzes (ABG), Entwurf 31.08.2017
Belgian Regulation	Pass	Royal decree of May 2015 (C-2014/24239)
Indoor Air Comfort <sup>®</sup>	Pass	Indoor Air Comfort 6.0 of February 2017
Indoor Air Comfort GOLD <sup>®</sup>	Pass	Indoor Air Comfort GOLD 6.0 of February 2017
EN 717-1 <sup>§</sup>	E1	2004
BREEAM International	Compliant	GN22 v2.3 (March 2018): BREEAM Recognised Schemes for VOC Emissions from Building Products
LEED v4 (outside U.S.)	Compliant	LEED v4 for Building Design and Construction (April, 2015)
BREEAM <sup>®</sup> NOR	Pass	BREEAM-NOR New Construction v1.1 (May 2017)

Full details based on the testing and direct comparison with limit values are available in the following pages

  
Malene Laugesen  
Analytical Service Manager

  
Rasmus Stengard Christensen  
Analytical Service Manager, MSc in Chemistry

The results are only valid for the tested sample(s).

This report may only be copied or reprinted in its entirety, parts of it only with a written acceptance by Eurofins.



# Attestation

On 3 April 2019, Eurofins Product Testing A/S received a sample of flooring with the product name:

## **BOSCHI DI FIEMME – ROVERE COLORATO**


supplied by

### **Fiemme 3000 - DKZ Srl**

The product was tested for VOC emissions according to the requirements of the French legislation (order of April 2011) concerning the labeling of construction products or coverings of walls or floors and paint and varnishes on their emissions of volatiles pollutants.

Sampling, testing and evaluation were performed according to ISO 16000 in its latest versions, see test report no. 392-2019-00134101\_A\_EN.

In accordance with legislative requirements, the test results can be summarized as follows:



\*Information sur le niveau d'émission de substances volatiles dans l'air intérieur, présentant un risque de toxicité par inhalation, sur une échelle de classe allant de A+ (très faibles émissions) à C (fortes émissions).

The product was assigned a VOC emission class without taking into account the measurement uncertainty associated with the result. As specified in French Decree no. 2011-321 of March 23, 2011, correct assignment of the VOC emission class is the sole responsibility of the party responsible for distribution of the product in the French market.

22 May 2019

  
Malene Laugesen  
Analytical Service Manager

  
Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry



# Confirmation

## LEED

On 3 April 2019, Eurofins Product Testing A/S received a sample of flooring with the product name:

### **BOSCHI DI FIEMME – ROVERE COLORATO**

supplied by

### **Fiemme 3000 - DKZ Srl**


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2019-00134101\_A\_EN).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:


**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of Indoor Air Comfort GOLD version 6.0 (February 2017).

22 May 2019



Malene Laugesen  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*